

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-1591:112

Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detectors

**LISTEE:** Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243  
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

**DESIGN:** Models 1230B, 1232B, 6266B, 6266B-001, 6269B, 6269B001, 6269B003, 6270B, 6270B001, 6270B003, 6270B100, 6270B200, 6266B100, 6266B200, 2430, 2432B, 9853-2, 9853-4, 9854-1, 9854-2, 9854-3 and 9854-4. Refer to listee's data sheet for detailed model description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as a photoelectric smoke detector for use with separately listed compatible control units and or bases.

**NOTE:** Formerly 7272-0073:126, 7257-0073:126 and 7272-1388:127

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager